

PROFORMA FOR SAFE DRINKING WATER AND SANITARY CONDITION CERTIFICATE

No. 2597 / WS-93 / 80

Dated: 13/11/2025

It is certified that an inspection team headed by Mansi Maheshwari (Chemist & Quality Manager)

(Name of Officers with designation) from U.P. Jal Nigam (Rural) Moradabad

inspected the St. Anthony's School, Bhojpur, Moradabad, Uttar Pradesh

(Name & Address of the school) on 11/11/2025 (Date of inspection) and on the basis of

Water Test Report (Attached) bearing no. 2596/WS-93/79 dated 13/11/25

Of U.P. Jal Nigam (Rural) Moradabad certified that the St. Anthony's School, Bhojpur

(Name of school) has safe drinking water facilities for the students and members of staff of the institution.

School is also maintains the hygienic sanitation condition in the school building & the campus as per norms

prescribed by the Central /State/UT. Govt.

This certificate is valid till One Year from the date of issue

Signature with Seal

Name Mansi Maheshwari

Designation Chemist (Quality Manager)

Name & Address of the Office/Department U.P. Jal Nigam (Rural)

Moradabad

To

St. Anthony's School

Bhojpur, Moradabad

Uttar Pradesh

(Name & Address of the Institution)



Water Analysis Report

District Level Water Analysis Laboratory U.P. Jal Nigam (Rural) Moradabad

Office of Executive Engineer, Khand Karyalay, U.P. Jal Nigam (Rural), Ashiyana Phase-1, Near OHT, Kanth Road, Moradabad

Report No	2596/LS-93/79	Date	13/11/2025	Page No.	1	
ULR No.						
Customer Details						
Name and Address	St Anthony's School, Bhojpur, Moradabad					
Ref Letter No. & Date						
Basic details of sample						
District	Moradabad	Block				
Gram Panchayat/ Nagar Panchayat		Village				
Habitation		Location	St Anthony's School			
Water Source	R.O.	Sample Code	C/25/11/1911			
Quantity of Sample	2 L	Date of Sample Collection	10-11-2025			
Receiving Date	10-11-2025	Sample Collector	Lalit Sharma			
Sample Depositor	Lalit Sharma	Sampling Method Used	IS 17614 (Part 1): 2021			
Analysis Start Date	10-11-2025	Analysis Completion Date	11-11-2025			
Environmental Condition during sampling: Temp./Humidity/Weather:						
Temperature	25 ± 3 °C		Humidity	50 ± 15%		
Technical Data of Analysis						
S.No.	Analysed Parameter	Units	Observed Value	Specified Values as per BIS 10500:2012 (Second Revision)		Ref. Method of Analysis
				Acceptable Limit	Permissible Limit	
1	2	3	4	5	6	7
1	Taste		Agreeable	Agreeable	Agreeable	IS 3025 (Part 8): 2023
2	Odour		Agreeable	Agreeable	Agreeable	IS 3025 (Part 5): 2018
3	Colour	HU	2	5	15	IS 3025 (Part 4): 2021
4	Turbidity	(NTU)	1.42	1.00	5.00	IS 3025 (Part 10): 2023
5	pH @ 25°C	-	7.36	6.5-8.5	No Relaxation	IS 3025 (Part 11): 2022
6	TDS	(mg/L)	186	500	2000	IS 3025 (Part 16): 2023
7	Chloride	(mg/L)	19	250	1000	IS 3025 (Part 32): 2019
8	Fluoride	(mg/L)	0.22	1	1.5	APHA 24th Edition -4500-F Method C (Electrode Method): 2023
9	Sulphate	(mg/L)	6.12	200	400	APHA 24th Edition -4500-SO ₄ Method E (Turbidimetric Method): 2023
10	Nitrate	(mg/l)	1.17	45	No Relaxation	APHA 24th Edition -4500-NO ₃ Method B (UV Screening Method): 2023
11	Iron	(mg/l)	0.37	1	No Relaxation	APHA 24th Edition -3500-Fe Method B (Phenanthroline Method): 2023
12	Total Hardness	(mg/l)	154	200	600	IS 3025 (Part 21): 2023
13	Total Alkalinity	(mg/l)	172	200	600	IS 3025 (Part 23): 2023
14	Calcium (As Ca)	(mg/l)	39.26	75.00	200.00	IS 3025 (Part 40): 2024
15	Magnesium (As Mg)	(mg/l)	13.60	30	100	IS 3025 (Part 46): 2023
All these parameters are under NABL Scope, BDL- Below Detection Limit, NA- Not Analysed						
1. This Certificate refers only to the particular sample(s) submitted for testing.						
2. This certificate shall not be reproduced, except in full, unless written permission for the publication of an approved abstract has been obtained from Head of Laboratory.						
3. The test results reported in this certificate are valid at the time of and under the stated conditions of measurements.						
4. Sample will be stored up to 7 days (in case of non perishable items only) from the date of issue of tests reports unless otherwise specified.						
5. If the sample is supplied by customer, the results apply to the sample as received.						
 Prepared By Deputy Technical Manager (Omkar Singh) Manager  Authorized Signatory Quality Manager (Mansi Maheshwari) Quality Manager						
****END OF THE ANALYSIS REPORT****						



Water Analysis Report

District Level Water Analysis Laboratory U.P. Jal Nigam (Rural) Moradabad
Office of Executive Engineer, Khand Karyalay, U.P. Jal Nigam (Rural), Ashiyana Phase-1, Near DHT, Kanth Road, Moradabad

Report No.	Date:		Page No. 1			
Customer Details						
Name and Address	St Anthony's School, Bhoojpur, Moradabad					
Ref Letter No. & Date						
Basic details of sample						
District	Moradabad	Block				
Gram Panchayat/ Nagar Panchayat		Village				
Habitation		Location	St Anthony's School			
Water Source	R.O.	Sample Code				
Quantity of Sample	1 L	Date of Sample Collection	10-11-2025			
Receiving Date	10-11-2025	Sample Collector	Lalit Sharma			
Sample Depositor	Lalit Sharma	Sampling Method Used	IS 17614 (Part 1) : 2021			
Analysis Start Date	10-11-2025	Analysis Completion Date	11-11-2025			
Environmental Condition						
Temperature	25 ± 3 °C		Humidity	50 ± 15%		
Technical Data of Analysis						
S.No.	Analysed Parameter	Units	Observed Value	Specified Values as per BIS 10500:2012 (Second Revision)		Ref. Method of Analysis
				Acceptable Limit	Permissible Limit	
1	2	3	4	5	6	7
1	Bacteriological	CFU/100 ml	0	(Shall not be detectable in any 100 ml sample)		IS 15185: 2016
Note						
1. This Certificate refers only to the particular sample(s) submitted for testing.						
2. This certificate shall not be reproduced, except in full, unless written permission for the publication of an approved abstract has been obtained from Head of						
3. The test results reported in this certificate are valid at the time of and under the stated conditions of measurements.						
4. Sample will be stored up to 7 days (in case of non perishable items only) from the date of issue of tests reports unless otherwise specified.						
5. Parameters above permissible limit are written in Bold.						
Prepared By (Abhishek Sagar)						
Authorized Signatory (Mansu Kumar Tiwari) Manager						
****END OF THE ANALYSIS REPORT****						